

## KEYED NOTES

- 1 INSTALL BALANCING VALVE WITH MINIMUM OF 3 STRAIGHT PIPE DIAMETERS UPSTREAM AND 1 STRAIGHT PIPE DIAMETER DOWNSTREAM.
- 2 MAINTAIN 6" MINIMUM CLEARANCE ABOVE TEST PLUG TO ALLOW GAUGE TO BE INSERTED. DON NOT COVER PLUG WITH INSULATION.
- 3 INSTALL SWING JOINTS AT COIL CONNECTIONS.
- 4 CONNECT BRANCH LINES FROM COIL INTO TOP OR SIDE OF SUPPLY & RETURN MAINS. CONNECTING INTO BOTTOM OF MAIN IS NOT ACCEPTABLE.
- 5 INSTALL MANUAL AIR VENTS IN SUPPLY & RETURN COIL BRANCH PIPING AS FOLLOWS:
  - A) IN PIPING HIGH POINT WHEN PIPING IS ABOVE MAIN.
  - B) CLOSE TO COIL WHEN PIPING NOT ABOVE MAIN (SIDE CONNECTION).



## FACILITY ENGINEERING MANUAL

COIL PIPING HOT WATER

(TOP/BOTTOM CONNECTIONS)
ON/OFF FLOW THROUGH COIL FAIL TO FULLHEAT

APPROVED: DISCIPLINE POC DATE:
DANNY NGUYEN 6-28-99

REVIEWER: DANNY NGUYEN

Los Alamos

Los Alamos National Laboratory Los Alamos, New Mexico 87545

otory 7 7545 0F

REV

CLASSIFICATION: U REFERENCE DOCUMENT:

DRAWING NUMBER:

CHAPTER 6 ST6121